



OptiClean™ D is a low pH cleaner developed specifically for the removal of metal(s) fouling, notably iron and manganese. It is also effective at removing inorganic scale. OptiClean™ D is designed to remove metal hydroxides from reverse osmosis, nanofiltration, ultrafiltration and microfiltration membranes.

Features / Benefits

- Contains chelants to remove metals
- Readily dissolvable powdered cleaner provides efficient shipping and handling
- Buffered pH to maintain optimum cleaning performance
- Can provide enhanced cleaning of system fouled by iron based coagulants

Uses

- For use on reverse osmosis (RO), microfiltration (MF), and ultrafiltration (UF) membranes
- For removal of fouling by oxides of iron and manganese
- Will also dissolve inorganic scaling on membrane surface

Specifications

Appearance	Off-white powder
pH (1% solution)	3.5 - 4.0

Packaging

Pail: 25 lbs/ 11.36 kg

Pail: 45 lbs/ 20.45 kg

For special packaging options, please contact PWT or your local distributor.



OptiClean™ D
POWDER MEMBRANE CLEANER

OptiClean™ D

POWDER MEMBRANE CLEANER



General Mixing & Application Instructions for OptiClean™ D

1. Inspect all cleaning system components to include CIP tank, hoses, and cartridge filters. Flush or replace if necessary. Fill cleaning tank with RO permeate or DI water. Turn on agitator or tank recirculation pump.
2. Slowly add OptiClean™ to cleaning tank (1 pound [0.45 kg] of OptiClean™ for every 12 gal [45 L] of water) and mix thoroughly. The solution pH should match product specification. If necessary, adjust pH with a membrane-approved chemical such as caustic, citric, sulfuric, or hydrochloric acid. The solution should be heated up to 45°C to improve cleaning efficacy.
3. Circulate solution in the same direction as the feed flow. Typical circulation times are 30-90 minutes.* PWT recommends cleaning each stage of the system separately. Maximum flow rate per pressure vessel is 40 gpm (152 Lpm) for 8-inch elements and 10 gpm (38 Lpm) for 4-inch elements. Maximum pressure for cleaning is 60 psig (4.2 kg/cm²).
4. In cases of heavy fouling, divert the first 10-20% of cleaning solution to drain to prevent redeposition of removed solids.
5. Rinse with RO permeate before returning system to service. When returning unit to service, divert product water to drain until any residual cleaning solution has been rinsed from system.

*Depending on the nature of the fouling, a soak period may be necessary for optimum results. Please contact PWT or your local distributor for custom cleaning procedure, or consult PWT's Technical Bulletin 503 for further cleaning recommendations.

ProDose XPRT™ – Scaling Prediction Software

ProDose XPRT™ uses the most accurate scaling prediction calculations available to accurately determine effective antiscalant dosage, and cleaning chemical usage. The user can enter multiple cases to study various operating conditions, directly enter concentrate analysis, and select the best PWT product and dosage for the application.

ProDose XPRT™ is available upon request only. Please contact your PWT representative for more information.

The screenshot displays the PWT ProDose software interface. At the top, there is a navigation bar with the PWT logo and several tabs: UNITS (US), TEMPERATURE (Fahrenheit), PERMEATE FLOW (81.00), RECOVERY (75.0%), ANTISCALANT (SpectraGuard Liquid), DOSAGE (2.95 PPM), SOURCE (Well Water), PROJECT NAME (Project 1), and CASE (1). Below this, a sidebar on the left contains icons for PROJECT INFORMATION, WATER QUALITY, SYSTEM INFORMATION, CHEMICAL SELECTION, CALCULATIONS, and REPORT. The main content area is divided into several sections: OVERVIEW (with fields for CLIENT NAME, PROJECT NAME, LOCATION, PREPARED BY, DATE, and WATER TYPE), MEASUREMENTS (with dropdowns for PRESET UNITS, TEMPERATURE, FLOW RATES, and MASS UNITS), COMMENTS (OPTIONAL) (a large text area), and TOTAL CASES (1 AVAILABLE) (a table with columns for Cases and Modified Date). The table shows one case with ID 1 and a modified date of 5/27/2016. Below the table is a section for Selected Case Description.



PWT Headquarters & Manufacturing
1048 La Mirada Court, Vista, California 92081

Toll-Free: 800.914.9072 | Direct: 760.639.4400 | Fax: 760.639.4439
Email: sales@pwtchemicals.com | www.pwtchemicals.com